



INITIAL OPTIMIZATION RESULTS BEND OPTIMIZED COLLECTION SYSTEM PLAN

November 21st, 2013

DRAFT RESULTS – SUBJECT TO CHANGE



AGENDA

- Welcome/Introduction
- Review of Nov 14 Takeaways
- Sensitivity Analysis
- CSMP Related Projects Update/Discussion
- Community Outreach
- Next Steps
- Nov 14 Questions
- Public Comment

























**City of Bend
Collection System Master Plan**


**Overall 2033
Optimization Alternatives**

November 2013



Legend


-  New Lift Station
 -  Decommissioned Lift Station
 -  Lift Station Upgrade
 -  Satellite Treatment
 -  Offline Storage
 -  Existing Sewer Pipe
- Alternatives**
-  Gravity Upgrade Along Existing Alignment
 -  Gravity Diversion
 -  Force Main Upgrade Along Existing Alignment
 -  Force Main Diversion
 -  New Pump Station Force Main
 -  Gravity or Force Main
 -  In-Line Linear Storage
 -  Flow Control Piping
 -  Planning Boundary
- Sewer Basin**
-  1
 -  2
 -  3
 -  4
 -  5
 -  6
 -  7
 -  8
 -  9



DRAFT RESULTS – SUBJECT TO CHANGE

All Options

40 YEAR LIFE CYCLE COSTS (MILLION DOLLARS)




DRAFT RESULTS – SUBJECT TO CHANGE

ALL OPTIONS (20-Year, Mid R)


Cost Item	Cost (\$M)
40-Y Life Cycle O&M Cost	32.20
40-Y Life Cycle Elect. Cost	1.20
40-Y Life Cycle Capital Cost	73.10
40-Y Total Life Cycle Cost	106.50

Initial Capital Cost	68.46
-----------------------------	--------------




DRAFT RESULTS – SUBJECT TO CHANGE

ALL OPTIONS (20-Year, High R)



Cost Item	Cost (\$M)
40-Y Life Cycle O&M Cost	36.10
40-Y Life Cycle Elect. Cost	0.40
40-Y Life Cycle Capital Cost	86.72
40-Y Total Life Cycle Cost	123.22

Initial Capital Cost	86.14
-----------------------------	--------------





HIGH LEVEL TAKEAWAYS

Solution Component	Trends Observed	Additional Refinement
General	<ul style="list-style-type: none"> • Similar solutions selected in both Mid R and High R • Cost difference between Mid R and High R • Upsizing existing infrastructure has higher life cycle costs 	<ul style="list-style-type: none"> • Model verification based on add. flow monitoring • Evaluate project phasing
Southeast Interceptor	<ul style="list-style-type: none"> • Always selected • Size relatively consistent with current design • 27th St alignment selected 	<ul style="list-style-type: none"> • Future growth sensitivity • Test Colorado extension
Colorado LS	<ul style="list-style-type: none"> • Always selected 	<ul style="list-style-type: none"> • Option to connect to SEI
Storage	<ul style="list-style-type: none"> • Three locations consistently selected for storage 	<ul style="list-style-type: none"> • Site specific costs
Northern System	<ul style="list-style-type: none"> • Northern Interceptor consistently selected • Upgrade of existing gravity/force mains not selected • Northwest Interceptor only selected in High R 	<ul style="list-style-type: none"> • OB Riley alignment and several other alignment alternatives to be included
Treatment	<ul style="list-style-type: none"> • Low treatment cost used to favor treatment • Treatment not selected 	<ul style="list-style-type: none"> • No further evaluation anticipated
Existing Lift Stations	<ul style="list-style-type: none"> • Decommission the majority of existing lift stations where gravity alternatives existed 	<ul style="list-style-type: none"> • Effect of phasing

PROPOSED SENSITIVITY ANALYSES

- ◆ To be conducted before January SIAG
 - Continued Mid R and High R evaluations
 - Growth Node Evaluation (next slide)
 - Water Conservation (10% reduction in dry loading)
 - Micro Optimization of North Area Common Force Mains and Lift Stations (in conjunction with O.B. Riley Rd. Alt.)
- ◆ Not currently recommended by City
 - OSU Growth Area (believed to be adequately covered in development of future planning data)

GROWTH NODES



DRAFT RESULTS – SUBJECT TO CHANGE

COLORADO LIFT STATION

- ◆ Colorado LS consistently selected
- ◆ 30% design complete in December
- ◆ Current capacity 2,300 gpm
- ◆ Dual 12-inch force mains
- ◆ Begin construction in Aug/Sep 2014
- ◆ Operational mid 2015

NORTH AREA SOLUTIONS

- ◆ NE Interceptor consistently selected
- ◆ Riverhouse diversion likely short-term solution
- ◆ Phasing needs to be confirmed
- ◆ Additional North Area options being evaluated
- ◆ North Area design team selected
- ◆ Design team will work with CSMP team to identify solution(s) over next few months

SE INTERCEPTOR

- SEI consistently selected
 - Regardless of credit for design costs
- Current design serves build-out of current UGB
- Key for growth/improvements in other areas
 - SEI creates capacity in central int. allowing city-wide growth
 - Colorado Lift Station
 - Riverhouse Diversion
- Continued refinement of solution by CSMP team unless directed otherwise by SIAG

SE INTERCEPTOR

What we know

- SEI consistently selected
 - Regardless of credit for design costs
- Current design serves build-out of current UGB
- Key for growth/improvements in other areas
 - SEI creates capacity in central int. allowing city-wide growth
 - Colorado Lift Station
 - Riverhouse Diversion
- Redesign will delay project approx. 1 year
- Low risk of stranded assets
- ROW acquisition issues

SE INTERCEPTOR

- What we don't know
 - Phasing of required improvements over next 20 years
 - Impact of additional growth on system
 - Impact of refined rainfall response
 - What other solutions may be identified through optimization process
 - Ability to accelerate the SEI construction
 - Construction sequencing
 - Financing capability

SE INTERCEPTOR QUESTIONS

- ◆ Is SIAG ready to make a recommendation related to SEI?

NEXT STEPS / INTERMEDIATE OPTIMIZATION

Input Refinement

- 💧 Site specific costs
- 💧 Review alignments
- 💧 Additional alternatives
- 💧 Review storage

Phasing Analyses

- 💧 10-year planning horizon



Sensitivity Analyses

- 💧 Wet-weather flow sensitivity analysis
- 💧 Loading sensitivity analysis (growth nodes)
- 💧 Indoor water conservation














**City of Bend
Collection System Master Plan**

**Overall 2033
Optimization Alternatives**

November 2013



Legend

-  Added Alternative
-  Initial Alternative
-  Existing Sewer Pipe
-  Planning Boundary
- Sewer Basin**
-  1
-  2
-  3
-  4
-  5
-  6
-  7
-  8
-  9

DRAFT RESULTS – SUBJECT TO CHANGE


All Options (Intermediate Runs)

SCHEDULE REVIEW



DRAFT CONDENSED PROJECT SCHEDULE (AS OF NOVEMBER 12, 2013)

CITY OF BEND OPTIMIZED SEWER COLLECTION SYSTEM MASTER PLAN



DRAFT RESULTS – SUBJECT TO CHANGE

OUTREACH SCHEDULE ITEMS

- ◆ Nov: Develop materials
- ◆ Nov-Dec: Schedule 2014 community briefings
- ◆ Jan-Feb: Community briefings / City communications
- ◆ Mid-March: Media Outreach
- ◆ April: Public open house / City communications