



Building Safety Division  
City of Bend  
(541) 388-5580 ext. 3  
building@bendoregon.gov  
710 NW Wall Street, Bend OR 97703

This submittal form is to be completed as part of your application with the City of Bend. *Download this form before completing fillable fields*, then upload with your application through the Online Permit Center at [www.bendoregon.gov/permitcenter](http://www.bendoregon.gov/permitcenter).

## FIRE ALARM SYSTEMS AFFIDAVIT FOR ALTERATIONS OR TENANT IMPROVEMENTS

Occupancy Type: \_\_\_\_\_ Construction Type: \_\_\_\_\_

Valuation of Work: \$ \_\_\_\_\_

Description of Work: \_\_\_\_\_

### Number of devices being added or moved under this permit process:

- New Communicator
- Smoke/Heat Detectors:    adding (max 5) \_\_\_\_\_                      moving (max 5) \_\_\_\_\_
- Alarm Stations:                      adding (max 5) \_\_\_\_\_                      moving (max 5) \_\_\_\_\_
- Notification Appliances:    adding (max 2) \_\_\_\_\_                      moving (max 5) \_\_\_\_\_

I, \_\_\_\_\_ certify the following is true and defines the scope of work for this project:

- a) All work complies with the current state-adopted NFPA-72 and the building code.
- b) All notification appliances are located in accordance with the current state-adopted NFPA-72.
- c) Smoke/Heat detector spacing complies with current state-adopted NFPA-72 and the building code.
- d) Exposed wiring will not be covered until inspected.
- e) Voltage drop is adequate to operate all appliances.
- f) Battery supplies can support the system modifications.
- g) Compatibility of appliances and devices are in accordance with the FACP manufacturer's specifications.
- h) Final approval shall be subject to on-site tests and inspections by City of Bend Building Safety Division and City of Bend Fire Department.
- i) The City of Bend Building Safety Division reserves the right to require additional plans and calculations.



### Accommodation Information for People with Disabilities

To obtain this information in an alternate format such as Braille, large print, electronic formats, etc. please contact the Building Safety Division at [building@bendoregon.gov](mailto:building@bendoregon.gov); (541) 388-5580 extension 3, Relay Users Dial 7-1-1.

In addition, I understand the following is required:

- Permit must be issued prior to work commencing
- A legible sketch illustrating the area of work within the building's structure
- Product cut sheets
- A copy of this document shall be provided on-site for all inspections
- End of line voltage tests required at acceptance test; system on DC, battery volts recorded, end of line voltage recorded in alarm condition, then adjusted to reflect voltage at end of battery life condition, 20.4. The remaining end of line voltage must be greater than the listed voltage for the devices on that circuit. Adjusted end of line voltage under 18 volts will require full battery calculations.

Applicant Signature: \_\_\_\_\_ Date: \_\_\_\_\_

**\*Registered Design Professional:**

*Required for Tenant Improvements in buildings greater than 4,000 square feet that require signature of registered design professional.*

Name: \_\_\_\_\_ Signature: \_\_\_\_\_

\*I have reviewed the Fire Alarm Systems submittal documents and found the design to be in general conformance to the design of the building.



**Accommodation Information for People with Disabilities**

To obtain this information in an alternate format such as Braille, large print, electronic formats, etc. please contact the Building Safety Division at [building@bendoregon.gov](mailto:building@bendoregon.gov); (541) 388-5580 extension 3, Relay Users Dial 7-1-1.