



MULTI-FAMILY RESIDENTIAL REBATE CHECKLIST

Pre-Inspection

INDOOR

Conditional approval for indoor devices may require:

- Access to units- occupied and/or vacant
- Assessment of devices to be replaced
 - Bathroom- gallons per flush
 - Laundry- gallons per load
- Estimated quantities of new devices
 - Bathroom- number of toilets, faucets, and showerheads
 - Laundry- number of washers
 - Pump- number of hot water recirculating pumps

OUTDOOR

Conditional approval for outdoor devices may require:

- Access to controller(s) and zone(s)
- Assessment of devices to be replaced
- Estimated quantities of new devices
 - HE Nozzles
 - PRS Bodies
 - PRS Rotors
 - Drip Kits
 - Smart Controllers
 - Irrigation Sub-Meter

Post-Inspection

INDOOR

Final approval for indoor devices will be determined through a combination of the following for bathroom, laundry, and recirculating pump rebates:

- Inspection of vacant units to verify installation AND/OR
- Verification of removed devices from units kept onsite for final device count AND/OR
- Inspection of a percentage of total units

OUTDOOR

Final approval for outdoor devices will be determined through a combination of the following for irrigation rebates:

- Efficiency test of distribution uniformity for set zones AND/OR
- Assessment of controller programming AND/OR
- Physical count of replaced heads/nozzles

