



# Food Truck Special Event Checklist

Code references per the 2022 Oregon Fire Code

## Fire Department Access

- Mobile food units shall not block fire hydrants or other fire appliances. 319.2.2

## Generators

- Generators shall not be refueled while in operation or operated in an enclosed area. 319.2.6
- Portable generators shall be positioned so that the exhaust is at least 5 feet (1524 m) in any direction away from any openings, air intakes or means of egress or from any building, structure, or vehicle.
- Vehicle mounted generators shall be installed, used and maintained in accordance with their listing and the manufacturer's instructions. 319.2.6.2

## Exits

- Means of egress must be kept clear of any obstructions. 319.2.7

## Fire Protection

- Exhaust Hood-Cooking equipment that produces smoke or grease-laden vapors shall be provided with a kitchen exhaust hood and an automatic fire-extinguishing system in accordance with Sections 606. 319.2.10 and 904.13
- Portable fire extinguishers shall be provided in accordance with Section 906.4 and 319.2.11.2
- A listed methane gas alarm shall be installed within the vehicle in accordance with manufacturer's instructions. 319.2.15.4
- An approved carbon monoxide alarm shall be installed where generators are used, or mobile cooking operations are performed in an enclosed area. 319.2.17

## Deep Fat Fryers and Oil

- Deep fat fryers shall comply with NFPA 96 and shall have a lid over the oil vat that can be secured to prevent the spillage of cooking oil during transit. This lid shall be secured at all times when the vehicle is in motion. 319.2.11.4

## LP-Gas Systems

- The maximum aggregate capacity of LP-gas containers transported on the vehicle and used to fuel cooking appliances only shall not exceed 200 pounds (91 kg) propane capacity. 319.2.14.2
- LP-gas containers installed on the vehicle shall be securely mounted and restrained to prevent movement. 319.2.14.3
- LP-gas system piping, including valves and fittings, shall be adequately protected to prevent tampering, impact damage, and damage from vibration. 319.2.14.5
- A listed LP-gas alarm shall be installed within the vehicle in the vicinity of LP-gas system components, in accordance with the manufacturer's instructions. 319.2.14.6

Language Assistance Services & Accommodation Information for People with Disabilities

You can obtain this information in alternate formats such as Braille, electronic format, etc. Free language assistance services are also available. Please contact Makayla Oliver at [moliver@bendoregon.gov](mailto:moliver@bendoregon.gov) or 541-323-8571. Relay Users Dial 7-1-1.

