



NOTES:

1. LOCATE THE WASHOUT A MINIMUM OF 50 FEET FROM ANY STORMWATER INLET AND/OR WATERBODY.
2. PREFABRICATED WASHOUT DEVICES MAY BE UTILIZED.

INSPECTION & MAINTENANCE:

3. INSPECT WEEKLY AND DAILY DURING STORM EVENTS.
4. WASHOUT FACILITIES MUST BE SERVICED OR REPLACED AND READY FOR USE ONCE THE FACILITY IS 75% FULL.
5. CONCRETE WASHOUT AREA TO BE REPAIRED AND/OR ENLARGED AS NECESSARY TO MAINTAIN CAPACITY FOR CONCRETE.
6. WASHOUT AREA TO BE REPAIRED AND/OR ENLARGED AS NECESSARY TO MAINTAIN CAPACITY FOR CONCRETE, WASHOUT AND SOLIDS.
7. UPON COMPLETION OF CONSTRUCTION ACTIVITIES, THE WASHOUT SHALL BE REMOVED AND THE AREA RESTORED TO FINISHED GRADE AND PRE-EXISTING CONDITIONS. CONTRACTOR TO LEGALLY DISPOSE OF WASTE MATERIALS.
8. CONTRACTOR SHALL TAKE PRECAUTIONS SO AS TO NOT OVERFLOW THE PIT.

DRAWN	CJH
DIV	EROSION
REV	DATE

CITY OF BEND
CONCRETE TRUCK WASHOUT

CITY OF BEND

STANDARD DRAWING

710 NW WALL ST., BEND, OREGON 97701

SCALE NTS

DATE 11/01/2024

APPR

STD DWG E-7